



**BUREAU  
VERITAS**

# Certificat de conformité

**Demandeur:** SMA Solar Technology AG  
Sonnenallee 1  
34266 Niestetal  
Allemagne

**Produit:** Onduleurs Photovoltaïques

**Modèle:** STP 50-40  
STP 50-41

Onduleur pour connexion parallèle triphasée au réseau public. Le dispositif de surveillance et de déconnexion du réseau fait partie intégrante du modèle susmentionné.

## Réglementations et normes appliquées:

**EN 50549-1:2019-02, NBN EN 50549-1:2019-02**

Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à des réseaux de distribution - Partie 1: Raccordement à un réseau de distribution BT - Centrales électriques jusqu'au Type B inclus

- 4.4 Plage de fonctionnement normale
- 4.5 Immunité aux perturbations
- 4.6 Réponse active à l'écart de fréquence
- 4.7 Réponse de puissance aux variations de tension et aux changements de tension
- 4.8 CEM et qualité de l'alimentation
- 4.9 Protection d'interface
- 4.10 Connexion et démarrage de la production d'énergie électrique
- 4.11 Arrêt et réduction de la puissance active au point de consigne
- 4.13 Exigences concernant la tolérance de panne unique du système de protection d'interface et du commutateur d'interface

**C10/11:2019-09**

Prescriptions techniques spécifiques de raccordement d'installations de production décentralisée fonctionnant en parallèle sur le réseau de distribution

**DIN V VDE V 0126-1-1:2006 (4.1 Sécurité fonctionnelle)**

Dispositif de déconnexion automatique entre un générateur et le réseau public à basse tension

**Règlement (UE) 2016/631 De La Commission du 14 avril 2016**

Etablissant un code de réseau sur les exigences applicables au raccordement au réseau des installations de production d'électricité. Homologation de type pour les unités de production à utiliser dans les installations de type A et de type B.

Un échantillon représentatif des produits mentionnés ci-dessus correspond à la date de la délivrance de ce certificat en vigueur des exigences de sécurité technique et pour l'utilisation conformément à sa destination.

**Numéro de rapport:** 17TH0199-EN50549-1\_1      **Programme de certification:** NSOP-0032-DEU-ZE-V01  
**Numéro de certificat:** U21-0153      **Délivré le:** 2021-02-16



Organisme de certification Bureau Veritas Consumer Products Services Germany GmbH accrédité par DIN EN ISO/IEC 17065

Une représentation partielle du certificat nécessite l'autorisation écrite de Bureau Veritas Consumer Products Services Germany GmbH



**Appendix**

Extract from test report according to EN 50549-1 / C10/11 Nr. 17TH0199-EN50549-1\_1

| Type Approval and declaration of compliance with the requirements of EN 50549-1 / C10/11.  |  |
|--|--|
| <b>Manufacturer / applicant:</b>   | SMA Solar Technology AG<br>Sonnenallee 1<br>34266 Niestetal<br>Germany |
| <b>Micro-generator Type</b>  | Photovoltaic inverter  |
|  | STP 50-40<br>STP 50-41   |
| <b>MPP DC voltage range [V]</b>  | 500 – 800  |
| <b>Input DC voltage range [V]</b>  | max. 1000  |
| <b>Input DC current [A]</b>  | 6 x 20   |
| <b>Output AC voltage [V]</b>   | 400  |
| <b>Output AC current [A]</b>   | 72,5   |
| <b>Output power [VA]</b>   | 50000  |
| <b>Firmware version</b>  | beginning with V03.10.03.R   |
| <b>Measurement period:</b>   | 2019-12-27 to 2020-02-12   |
| <b>Description of the structure of the power generation unit:</b><br>The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error. |  |



**Appendix**

Extract from test report according to EN 50549-1 / C10/11

Nr. 17TH0199-EN50549-1\_1

**Type Approval and declaration of compliance with the requirements of EN 50549-1 / C10/11 and Commission Regulation (EU) 2016/631 of 14 April 2016**

**Parameter Table:**

| Clause EN 50549-1   | Ref  | Parameter  | Micro generator setting range | Default settings used                             |          |
|---|------|--|-------------------------------|---|----------|
| 4.3.2 Interface switch  | n.a. | Single fault tolerance for interface switch  | yes   no                      | yes   |          |
| 4.4.2 Operating frequency range   | A,B  | 47,0 – 47,5 Hz Duration  | 0 – 20 s                      | 0,3 s   |          |
|   | A,B  | 47,5 – 48,5 Hz Duration  | 30 – 90 min                   | unlimited   |          |
|   | A,B  | 48,5 – 49,0 Hz Duration  | 30 – 90 min                   | unlimited   |          |
|   | A,B  | 49,0 – 51,0 Hz Duration  | not configurable              | unlimited   |          |
|   | A,B  | 51,0 – 51,5 Hz Duration  | 30 – 90 min                   | unlimited   |          |
|   | A,B  | 51,5 – 52 Hz Duration  | 0 – 15 min                    | 0,1 s   |          |
| 4.4.3 Minimal requirement for active power delivery at under frequency    | A,B  | Reduction threshold  | 49 Hz – 49,5 Hz               | Electronic inverter no power reduction take place |          |
|   | A,B  | Maximum reduction rate   | 2 – 10 % P <sub>M</sub> /Hz   | ≤ 2 %   |          |
| 4.4.4 Continuous operating voltage range                                  | n.a. | Upper limit  | 100 – 110%                    | N/A   |          |
|   | n.a. | Lower limit  | 90 – 100%                     | N/A   |          |
| 4.5.2 Rate of change of frequency (ROCOF) immunity                        | A,B  | ROCOF withstand capability (defined with a sliding measurement window of 500 ms)<br>non-synchronous generating technology:<br>synchronous generating technology: | not defined                   | 2,5 Hz/s  |          |
| 4.5.3.2 Generating plant with non-synchronous generating technology (FRT) | B    | Maximum power resumption time  | not defined                   | ≤1 s  |          |
|   | B    | Voltage-Time-Diagram   | see Figure 6, EN 50549-1      | Time [s]  | U [p.u.] |
|   |      |  |                               | 0,0   | 0,05     |
|   |      |  |                               | 0,25  | 0,05     |
| 3   | 0,85 |  |                               |   |          |
| 4.5.3.3 Generating plant with synchronous generating technology (FRT)     | B    | Maximum power resumption time  | not defined                   | N/A   |          |
|   | B    | Voltage-Time-Diagram   | see Figure 7, EN 50549-1      | Time [s]  | U [p.u.] |
|   |      |  |                               | N/A   | N/A      |
|   |      |  |                               | N/A   | N/A      |
|   |      |  |                               | N/A   | N/A      |
|   |      |  |                               | N/A   | N/A      |
| N/A   | N/A  |  |                               |   |          |



Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 17TH0199-EN50549-1\_1

|   |      |                                       |   |                 |          |
|---|------|---------------------------------------|---|-----------------|----------|
| 4.5.4 Over-voltage ride through (OVRT)                                    | n.a. | Voltage-Time-Diagram                  | not configurable  | Time [s]        | U [p.u.] |
|   |      |                                       |   | N/A             | N/A      |
|   |      |                                       |   | N/A             | N/A      |
|   |      |                                       |   | N/A             | N/A      |
|   |      |                                       |   | N/A             | N/A      |
|   |      |                                       |   | N/A             | N/A      |
|   |      |                                       |   | N/A             | N/A      |
| 4.6.1 Power response to over frequency (LFSM-O)                           | A,B  | Threshold frequency $f_1$             | 50,2 Hz – 52 Hz   | 50,2 Hz         |          |
|   | A,B  | Drop                                  | 2 % – 12 %  | 5 %             |          |
|   | A,B  | Power reference                       | $P_M$   $P_{max}$   | $P_M$           |          |
|   | n.a. | Intentional delay                     | 0 – 2 s   | 0 s             |          |
|   | n.a. | Deactivation threshold $f_{stop}$     | 50,0 Hz – $f_1$   | deactivated     |          |
|   | n.a. | Deactivation time $t_{stop}$          | 0 – 600 s   | -               |          |
|   | A    | Acceptance of staged disconnection    | yes   no  | No              |          |
| 4.6.2 Power response to under frequency                                   | n.a. | Threshold frequency $f_1$             | 49,8 Hz – 46 Hz   | N/A             |          |
|   | n.a. | Drop                                  | 2 – 12 %  | N/A             |          |
|   | n.a. | Power reference                       | $P_M$   $P_{max}$   | N/A             |          |
|   | n.a. | Intentional delay                     | 0 – 2 s   | N/A             |          |
| 4.7.2.2 Capabilities  | B    | Active factor range overexcited       | 0,9 – 1   | 0,9             |          |
|   | B    | Active factor range underexcited      | 0,9 – 1   | 0,9             |          |
| 4.7.2.3 Control modes   | n.a. | Enabled control mode                  | Q setp.<br>Q(U)<br>cos $\varphi$ setp.<br>cos $\varphi$ (P) | All can be set! |          |
| 4.7.2.3.2 Set point control modes   | n.a. | Q setpoint and excitation             | 0 – 48 % $P_D$  | 0               |          |
|   | n.a. | cos $\varphi$ setpoint and excitation | 1 – 0,9   | 1               |          |
| 4.7.2.3.3 Voltage related control modes                                   | n.a. | Characteristic curve                  | Q(U)<br>P(U)  | disabled        |          |
|   | n.a. | Time constant                         | 3 s – 60 s  | 10 s            |          |
|   | n.a. | Min cos $\varphi$                     | 0,0 – 1   | 0,9             |          |
|   | n.a. | Lock in power                         | 0 % – 20 %  | deactivated     |          |
|   | n.a. | Lock out power                        | 0 % – 20 %  | deactivated     |          |
| 4.7.2.3.4 Power related control mode                                      | n.a. | Characteristic curve                  | cos $\varphi$ (P)   | disabled        |          |
| 4.7.4.2.2 Zero current mode for converter connected generating technology | n.a. | Enabling                              | enable   disable  | disabled        |          |
|   | n.a. | Static voltage range overvoltage      | 100 % $U_n$ – 120 % $U_n$                                   | N/A             |          |
|   | n.a. | Static voltage range undervoltage     | 20 % $U_n$ – 100 % $U_n$                                    | N/A             |          |



BUREAU  
VERITAS

Annex to the EN 50549-1 / C10/11 certificate of compliance No. U21-0153

Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 17TH0199-EN50549-1\_1

|  |  |  |                           |                            |
|--|--|--|---------------------------|----------------------------|
| 4.9.2 Requirements on voltage and frequency protection | n.a                                    | Threshold for protection as dedicated device [in A or kW, kVA] | 16 A – 250 kVA            | N/A                        |
|  | B                                      | Undervoltage threshold stage 1                                 | $0,2 U_n - 1 U_n$         | $0,8 U_n$                  |
|  | B                                      | Undervoltage operate time stage 1                              | 0,1 s – 100 s             | 0,1                        |
|  | B                                      | Undervoltage threshold stage 2                                 | $0,2 U_n - 1 U_n$         | N/A                        |
|  | B                                      | Undervoltage operate time stage 2                              | 0,1 s – 5 s               | N/A                        |
|  | B                                      | Overvoltage threshold stage 1                                  | $1,0 U_n - 1,2 U_n$       | $1,15 U_n$                 |
|  | B                                      | Overvoltage operate time stage 1                               | 0,1 s – 100 s             | 0,1 s                      |
|  | B                                      | Overvoltage threshold stage 2                                  | $1,0 U_n - 1,3 U_n$       | disable                    |
|  | B                                      | Overvoltage operate time stage 2                               | 0,1 s – 5 s               | disable                    |
|  | B                                      | Overvoltage threshold 10 min mean protection <sup>a</sup>      | $1,0 U_n - 1,15 U_n$      | $1,1 U_n$                  |
|  | B                                      | Overvoltage operate time 10 min mean protection <sup>a</sup>   | 0 – 3 s                   | 10 min (update every 0,1s) |
|  | B                                      | Underfrequency threshold stage 1                               | 47,0 Hz – 50,0 Hz         | 47,5 Hz                    |
|  | B                                      | Underfrequency operate time stage 1                            | 0,1 s – 100 s             | 0,3 – 0,5 s                |
|  | B                                      | Underfrequency threshold stage 2                               | 47,0 Hz – 50,0 Hz         | N/A                        |
|  | B                                      | Underfrequency operate time stage 2                            | 0,1 s – 5 s               | N/A                        |
|  | B                                      | Overfrequency threshold stage 1                                | 50,0 Hz – 52,0 Hz         | 52,0 Hz                    |
|  | B                                      | Overfrequency operate time stage 1                             | 0,1 s – 100 s             | 0,3-0,5s                   |
|  | B                                      | Overfrequency threshold stage 2                                | 50,0 Hz – 52,0 Hz         | N/A                        |
|  | B                                      | Overfrequency operate time stage 2                             | 0,1 s – 5 s               | N/A                        |
| B  | Loss of mains according EN 62116 (LoM) | 0-6000s  | 2 s                       |                            |
| 4.10.2 Automatic reconnection after tripping           | B                                      | Lower frequency  | 47,0 Hz – 50,0 Hz         | 49,9 Hz                    |
|  | B                                      | Upper frequency  | 50,0 Hz – 52,0 Hz         | 50,1 Hz                    |
|  | B                                      | Lower voltage  | $50 \% U_n - 100 \% U_n$  | $85 \% U_n$                |
|  | B                                      | Upper voltage  | $100 \% U_n - 120 \% U_n$ | $110 \% U_n$               |
|  | B                                      | Observation time   | 10 s – 600 s              | 60 s                       |
|  | B                                      | Active power increase gradient                                 | 6 % – 3000 %/min          | 9 % /min                   |
| 4.10.3 Starting to generate electrical power           | A,B                                    | Lower frequency  | 47,0 Hz – 50,0 Hz         | 49,9 Hz                    |
|  | A,B                                    | Upper frequency  | 50,0 Hz – 52,0 Hz         | 50,1 Hz                    |
|  | A,B                                    | Lower voltage  | $50 \% - 100 \% U_n$      | $85 \% U_n$                |
|  | A,B                                    | Upper voltage  | $100 \% - 120 \% U_n$     | $110 \% U_n$               |
|  | A,B                                    | Observation time   | 10 s – 600 s              | 60 s                       |
|  | A,B                                    | Active power increase gradient                                 | 6 % – 3000 %/min          | 19 %/min                   |



BUREAU  
VERITAS

## Annex to the EN 50549-1 / C10/11 certificate of compliance No. U21-0153

### Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 17TH0199-EN50549-1\_1

|   |     |  |          |    |
|---|-----|--|----------|----|
| 4.11.1 Ceasing active power                   | A,B | Remote operation of the logic interface  | yes   no | No |
| 4.11.2 Reduction of active power on set point | B   | Remote operation<br>NOTE: If yes further definition is provided by the DSO                     | yes   no | No |
| 4.12 Remote information exchange              | B   | Remote information exchange required<br>NOTE: If yes further definition is provided by the DSO | yes   no | No |

#### Note:

<sup>a</sup> Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.

The settings of the interface protection are password protected adjustable in the stated range above.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 / C10/11:2019 and Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.