


Certificate of Conformity

Certificate Number: CN-PV-220215

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen SOFARSOLAR Co., Ltd. 11/F., Gaoxinqi Technology Building, No.67 Area, Xingdong Community, Xin'an Sub-district, Bao'an District, Shenzhen City, China
Product:	Inverter Module
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	ESI 3K-S1, ESI 3.68K-S1, ESI 4K-S1, ESI 4.6K-S1, ESI 5K-S1, ESI 5K-S1-A, ESI 6K-S1
Brand Name<s>:	
Product Complies with:	C10/11: ed.2.2 2021 SPECIFIC TECHNICAL PRESCRIPTIONS REGARDING POWER-GENERATING PLANTS OPERATING IN PARALLEL TO THE DISTRIBUTION NETWORK
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	220824076GZU-001

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 13 October 2022



PRD N° 306B

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-220215.

MODEL	ESI 3K-S1	ESI 3.68K-S1	ESI 4K-S1	ESI 4.6K-S1
Max.DC input voltage	550Vdc			
MPPT voltage range	85~520Vdc			
Max.PV Isc	2*22.5A			
Rated battery voltage	400V			
Max.charging/discharging current	20A			
Max.charging/discharging power	3000W	3680W	4000W	4600W
Rated grid voltage	230V,50Hz			
Rated output voltage	230V,50/60Hz			
Max.output current	15A	16A	20A	20.9A
Power Factor	1 default (adjustable+/-0.8)			
Rated output power	3000W	3680W	4000W	4600W
Rated apparent power	3000VA	3680VA	4000VA	4600VA
Ambient Temperature	-10~ +50°C			
Protection Degree	IP65			
Protection Class	Class I			
Inverter topology	Non-Isolated			
Overvoltage Category	AC III, DC II			
safety firmware version:	V000001			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-220215.

MODEL	ESI 5K-S1	ESI 5K-S1-A	ESI 6K-S1
Max.DC input voltage	550Vdc		
MPPT voltage range	85~520Vdc		
Max.PV Isc	2*22.5A		
Rated battery voltage	400V		
Max.charging/discharging current	20A		
Max.charging/discharging power	5000W	5000W	6000W
Rated grid voltage	230V,50Hz		
Rated output voltage	230V,50/60Hz		
Max.output current	25A	22.7A	30A
Power Factor	1 default (adjustable+/-0.8)		
Rated output power	5000W	5000W	6000W
Rated apparent power	5000VA	5000VA	6000VA
Ambient Temperature	-10~ +50°C		
Protection Degree	IP65		
Protection Class	Class I		
Inverter topology	Non-Isolated		
Overvoltage Category	AC III, DC II		
safety firmware version:	V000001		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.