

Certificate of Conformity

By the product certificate number

No. 2621/0077-CER

Issued to

License holder: Shenzhen SOFARSOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68,
XingDong Community, XinAn Street, BaoAn District.
Shenzhen City, Guangdong Province, P.R. China



Manufacturer: Dongguan SOFAR SOLAR Co., Ltd.
1F – 6F, Building E, No.1 JinQi Road, Bihu Industrial Park.
Wulian Village, Fenggang Town, Dongguan, P.R. China.

Trademark:



It is certified that the product:

Type of generator: PV Inverter

Models:	SOFAR 75KTL	SOFAR 80KTL	SOFAR 100KTL	SOFAR 110KTL	SOFAR 100KTL-HV	SOFAR 125KTL-HV	SOFAR 136KTL-HV
Technical Data:							
Nominal Power	75 kW	80 kW	100 kW	110 kW	100 kW	125 kW	136 kW
Nominal Voltage	230/400 V	230/400 V	230/400 V	230/400 V	500 V	500 V	540 V
Nominal Frequency	50 Hz	50 Hz	50 Hz	50 Hz	50 Hz	50 Hz	50 Hz
Firmware version	(1)	(1)	(1)	(1)	(1)	(1)	(1)
Number of phases	3/N/PE	3/N/PE	3/N/PE	3/N/PE	3/PE	3/PE	3/PE
Isolation transformer	NO	NO	NO	NO	NO	NO	NO

(1) FW version is: DSPM: ARM V020010; DSPS V020010; DSPM V020010

Is in compliance with the regulation:

- Technical Prescription C10/11 of Synergrid. Edition 2.1 (01.09.2019)

Compliant with requirements for:

- Technical requirements for connection of power generating plants of Type A and B to the low voltage grid (≤ 1 kV)

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 14th April 2021.
This certificate is valid until 14th April 2024.

Madrid, 14th April 2021

Daniel Arranz Muñoz
Certification Manager

