

Certificate of compliance

Applicant:	Solenso electronic materials Co., LTD. 4F., NO.56, ZILI 5TH ST., ZHONGLI DIST., TAOYUAN CITY 320, TAIWAN			
Product:	Photovoltaic (PV) inverter			
Model:	Sol-H600, Sol-H700, Sol-H800, Sol-H900, Sol-H1000, Sol-H600H, Sol-H700H, Sol-H800H, Sol-H900H, Sol-H1000H			

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

4.4 Normal operating range

- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	BMH-ESH-P22120903	TIERU Certification Program	NSOP-0032-DEU-ZE-V01
Certificate number:	U23-0216	Date of issue:	2023-06-13
	In the second se	Certification body	
		chow hamp in	DAkkS
	4 7 8	Alf Assenkamp	Akkreditierungsstelle D-ZE-12024-01-00
Certification L	body Bureau Veritas Consumera	Products Services Germany GmbH accreditation to	DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Appendix

Type Approval and declaration 2016/631 of 14 April 2016	n of compliance wit	h the requirements	of EN 50549-1 and	Commission Reg	ulation (EU)		
Manufacturer / applicant	Solenso electronic materials Co., LTD. 4F., NO.56, ZILI 5TH ST., ZHONGLI DIST., TAOYUAN CITY 320, TAIWAN						
Micro-generator Type	Photovoltaic inverte						
	Sol-H600	Sol-H700	Sol-H800	Sol-H900	Sol-H1000		
Max.DC voltage	60 Vd.c.						
MPPT voltage range	16-48 Vd.c.						
Max. PV current	2*13 Ad.c.	2*13 Ad.c.	2*13,5 Ad.c.	2*14 Ad.c.	2*14,5 Ad.c		
Rated grid voltage	L/N/PE, 230 Va.c., 50 Hz						
Max. AC Output current	2,61 Aa.c.	3,04 Aa.c.	3,48 Aa.c.	3,91 Aa.c.	4,26 Aa.c.		
Max. AC Output active Power	600 VA	700 VA	800 VA	900 VA	980 VA		
	Sol-H600H	Sol-H700H	Sol-H800H	Sol-H900H	Sol-H1000H		
Max.DC voltage	60 Vd.c.						
MPPT voltage range	16-48 Vd.c.						
Max. PV current	2*13 Ad.c.	2*13 Ad.c.	2*13,5 Ad.c.	2*14 Ad.c.	2*14,5 Ad.c		
Rated grid voltage	L/N/PE, 230 Va.c., 50 Hz						
Max. AC Output current	2,61 Aa.c.	3,04 Aa.c.	3,48 Aa.c.	3,91 Aa.c.	4,26 Aa.c.		
Max. AC Output active Power	600 VA	700 VA	800 VA	900 VA	980 VA		
	V01.00.04						

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has galvanic isolation between DC input and AC output (HF transformer). Output switch-off is performed with single-fault tolerance based on the inverter bridge and one series-connected relay in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.