

Certificate of Conformity

By the product certificate number:

No. 250041RECO01-C-CER

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



Contract number: 802190

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Product Family: Multiplus II - 3phase configuration

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Rated Frequency		50 Hz	
Firmware version	2621552	2627552	2619552
Number of phases		Three Phase ⁽¹⁾ (3L/N/PE)	
Isolation transformer		Yes	

(1) The three-phase system consists of three individual inverters (of the same model) placed in parallel.
(1) See on page 2 installation scheme.

Is in compliance with the standard:

- Technical Prescription C10/11 of Synergrid. Edition 2.2 (15.03.2021) ⁽²⁾

⁽²⁾ Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

This certificate is based upon test results offered in the test report No. 2222/0478-C issued on 05th July 2023.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 21st February 2025.

This certificate is valid until the 21st February 2030.

Madrid, 21st February 2025

Daniel Arranz Muñiz
Certification Manager



SGS Tecnos, S.A.U. C/ Trespaderne, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions.
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).
This document cannot be reproduced partially



No. 250041RECO01-C-CER

Page 1 of 2

Installation scheme:

